

Certificate

Applicant: TELE Haase Steuergeräte Ges.m.b.H
Vorarlberger Allee 38
1230 Wien
Austria

Product: Protection Relay

Model: NA003

Intended use:

Automatic disconnection device with three-phase mains surveillance in accordance with VDE 0126-1-1 for systems with a three-phase parallel coupling to the public mains supply.

Applied standards and guidelines:

DIN VDE 0126-1-1 (VDE V 0126-1-1):2013-08

Automatic disconnection device between a generator and the public low-voltage grid

The safety concept of an aforementioned representative product corresponds at the time of issue of this certificate to the valid safety specifications for the specified use in accordance with regulations.

Report No: 14PP035

Certificate No: 15-076-00

Date of issue: 2015-04-23



A handwritten signature in black ink, appearing to read "A. Aufmuth", is positioned above the name of the certification body.

Andreas Aufmuth
Certification Body

