

Certificate

Applicant: **TELE Haase Steuergeräte Ges.m.b.H**
Vorarlberger Allee 28
1230 Wien
Austria

Product: **Protection Relay**

Model: **NA003**

Intended use:

Automatic disconnection device with three-phase mains surveillance for systems with a three-phase parallel coupling via an inverter in the public mains supply.
The interface protection does not provide an active islanding detection method.

Applied standards and guidelines:

SOP-9-1_11 GCC Certification Program, 04/18

Based on:

NRS 097-2-1:2017

Grid interconnection of embedded generation
Part 2: Small-scale embedded generation
Section 1: Utility interface

The safety concept of an aforementioned representative product corresponds at the time of issue of this certificate to the valid safety specifications for the specified use in accordance with regulations.

Report No: 14PP035-12

Certificate No: 18-315-00

Date of issue: 2018-09-20



Tanja Rottach
Certification Engineer

